

(27) Subsection 4.6.1. Installations in Sleeping Quarters: Delete as written and substitute the following: "Room heaters installed as the only means of heat in rooms used for sleeping or bathing purpose shall be of the sealed combustion chamber type which take their air for combustion from, and discharge the flue gas to, the outside atmosphere."

"Room heaters installed as means of supplementary heat in rooms used for sleeping or bathing purposes shall be as above or of the vented type. The vented type heater shall be connected to an effective chimney or gas vent and be equipped with an automatic pilot."

(28) Subsection 4.6.3. Clearance. Delete the second paragraph including the deletion of "(a)" and "(b)".

(29) Subsection 4.7.1. Independent Gas Piping: Delete entire subsection.

(30) Subsection 4.7.3. Clearance: Delete from Table 11 lines II and IV pertaining to "unlisted" and delete footnotes "6" and "9".

(31) Subsection 4.7.3. (b). Delete THE SECOND SENTENCE OF THE first paragraph of Subsection 4.7.3. (b). and substitute the following: ~~Central heating furnaces and boilers installed in confined spaces must be installed in accordance with their listing and when such units are installed in spaces such as alcoves and closets, they must be specifically listed for such installations.~~

(32) Subection 4.7.10. Plenum Chambers and Air Ducts. Delete Subsection 4.7.10 (c) and substitute the following: "(c) When the furnace is installed within a confined space, or not within the heated space, the air circulated by the furnace shall be handled by ducts which are sealed to the furnace casing, entirely separate from the means provided for supplying combustion and ventilation air, and connected to the heated space and/or to the outside air."

(33) Subsection 4.9.7. Clearance: Delete the last two sentences starting with "When these...." and substitute the following: "Where the burner or controls must be serviced from the bottom of the floor furnace, sufficient additional clearance must be provided to permit their removal."

(34) Subsection 4.9.8. Access: Change title to "Pit to Be Provided", delete as written and substitute the following: "Where the distance between the floor joists and the ground level is less than 30 inches or the bottom of the floor furnace does not have the required clearances, a pit must be provided under the floor furnace. The access passageway and the bottom of the pit must have a minimum clearance of 30 inches from the bottom of the floor joists. The pit shall be sized to give a clearance of eighteen (18) inches on the control and vent collar sides. If the control and vent collar sides are adjacent to each other, the clearance on the remaining two sides may be reduced to 6 inches. The access passageway (see 4.9.9) must enter the pit at the control side where the 18-inch clearance is provided. The sides and bottom of the pit shall be lined with concrete or concrete block to extend 4 inches above the ground level and shall connect with the concrete sides of the access passageway (see 4.9.9). The bottom of the pit may be covered with 2 inches of crushed stone, gravel, or similar material in lieu of concrete, if desired."

(35) Subsection 4.9.9. Seepage Pan: Change title to "Access", delete as written and substitute the following: "Provision shall be made for access to the floor furnace by means of a trap door of at least 24 inches by 24 inches, located at some convenient portion of the house